

# Slip test results

## FMR104

Classic Tredfx Aluminium Safety Stair Nosing with Aluminium Insert



A division of Safe Environments Pty Ltd  
www.SafeEnvironments.com.au

4/40 Bessemer Street  
Blacktown NSW 2148  
Phone 02 9621 3706  
ABN 80 118 534 768

4 April 2016

### Test Report No. R8664

#### Slip Resistance Classification of New Pedestrian Surface Materials

AS 4586:2013 Appendix A (Wet Pendulum Test)

The slip resistance Classification has been determined for unused surfaces using specific conditions. Factors such as usage, cleaning systems, applied coatings and patterns of wear may affect the characteristics of the surface.

Requested by: Tredfx / Classic Architectural  
Client Address: PO Box 126  
Preston VIC 3072  
Product Manufacturer: Supplied by Classic Architectural  
Product Description: Tredfx Ribbed Aluminium Floor safety staimosing (SNR019, SNB031, INB033)

Test conducted according to: AS 4586:2013 Appendix A  
Location: Slip Check Pty Ltd Test Facilities, Blacktown NSW 2148  
Conducted by: Stuart Lumsden

Date: 2 March 2016  
Sample: Unfixed  
Rubber slider used: Slider 96  
Slope of specimen: Tested on a flat level surface  
Direction of Test: Perpendicular to ribbed surface

Temperature: 20°C  
Cleaning: None  
Conditioned: Grade P 400 paper dry followed by wet lapping film

	Specimen 1	Specimen 2	Specimen 3	Specimen 4	Specimen 5
Mean BPN of last 3 swings:	46	45	47	44	46

Reported SRV of Sample:	45
Class:	P4



*R. Voorderhake*

Ryan Voorderhake  
Laboratory/Field Technician

Safe Environments Pty Ltd  
R8664 - Slip Check, Tredfx staimosings  
4 April 2016