

Slip test results

SBR135

Classic Tredfx Aluminium Safety Stair Nosing with Poly insert



A division of Safe Environments Pty Ltd
www.SafeEnvironments.com.au

4/40 Bessemer Street
Blacktown NSW 2148
Phone 02 9621 3706
ABN 80 118 534 768

4 April 2016

Test Report No. R8663

Slip Resistance Classification of New Pedestrian Surface Materials

AS 4586:2013 Appendix A (Wet Pendulum Test)

The slip resistance Classification has been determined for unused surfaces using specific conditions. Factors such as usage, cleaning systems, applied coatings and patterns of wear may affect the characteristics of the surface.

Requested by: Tredfx / Classic Architectural
Client Address: PO Box 126
Preston VIC 3072
Product Manufacturer: Supplied by Classic Architectural
Product Description: Tredfx 'B' Ribbed Polymer Floor safety inserts for stairnosing (black and yellow)

Test conducted according to: AS 4586:2013 Appendix A
Location: Slip Check Pty Ltd Test Facilities, Blacktown NSW 2148
Conducted by: Stuart Lumsden


Date: 2 March 2016
Sample: Unfixed
Rubber slider used: Slider 96
Slope of specimen: Tested on a flat level surface
Direction of Test: Perpendicular to ribbed surface

Temperature: 20°C
Cleaning: None
Conditioned: Grade P 400 paper dry followed by wet lapping film

| | Specimen 1 | Specimen 2 | Specimen 3 | Specimen 4 | Specimen 5 |
|----------------------------|------------|------------|------------|------------|------------|
| Mean BPN of last 3 swings: | 43 | 45 | 42 | 44 | 45 |

| | |
|-------------------------|----|
| Reported SRV of Sample: | 44 |
| Class: | P3 |




Ryan Voorderhake
Laboratory/Field Technician

Safe Environments Pty Ltd
R8663 - Slip Check, Tredfx inserts
4 April 2016